

VOC Content Test Certificate

Thursday 22th August 2019

Supplier: Flowcrete Australia Pty Ltd (Unit 2, 41 Deakin Street, Brendale, QLD, 4500).

Sample Description: Flowcrete Deckshield PDS Membrane

Date Tested: August 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D2369-10: 2015 Standard Test Method for Volatile Content of Coatings: Table

1 – Method E with 3% of BPO catalyst, Pot time of 10 minutes and Induction time of 24 hours in sealed containers before putting in oven.

Test Data:

<p align="center">Specification</p> <p align="center">Green Building Council of Australia Green Star Design & As Built V1.2-13.1.1B Green Star Interiors V1.2-12.1.1B</p>	<p align="center">Deckshield PDS Membrane</p>
<p>Acoustic sealants, architectural sealant, waterproofing membranes and sealant, fire retardant sealants and adhesives: 250 grams per Litre</p>	<p align="center">26 grams per Litre as VOC content per material</p>
<p align="center"><i>We hereby certify that Deckshield PDS Membrane is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Luke Morley
BSc (Tech)
Consultant

V1907042A